



NOTE: 1) 2) WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
 1) HYDRO @ 195 PSIG. MIN.

SHELL / HEADS		M.A.W.P. 150 PSIG. @ 200 °F	
.166" SA-414-F 2:1 S.E.		M.D.M.T. 0 °F @ 150 PSIG.	
JOGGLE - .149 OFFSET		ASME SECTION VIII DIV. 1, 2007 ADD 2009	
.165" SA-414-G		X-RAY: RT-NO	
		GALLONS: 200	
		WT. 514 LBS.	
		SERIAL NO.	
		N.B.	
FOR: HANSON STANDARD		BY: J.G.	
VERT. CHILLED WATER TANK		SCALE: 1"=12"	
INSIDE: UNPAINTED		ROY E. HANSON JR. MFG.	
OUTSIDE: SHOP PRIME		1600 E. WASHINGTON BLVD.	
		LOS ANGELES, CA 90021	
WL-264-B		REV. 1-22-10	
		DATE: 10-4-05	