



.135"THK. BAFFLE
PER: WL-264-B-1A

2) WELD 3/4"Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
NOTE: 1) HYDRO @ 195 PSIG. MIN.

SHELL / HEADS	.140" SA-414-G 2:1 S.E.	
	JOGGLE	
	.165" SA-414-G	
M.A.W.P.	150 PSIG. @	200 °F
M.D.M.T.	0 °F @	150 PSIG.
ASME. SECTION VIII DIV. 1, 2007 ADD 2008		
X-RAY:	RT-NO	
GALLONS:	200	WT. 438 LBS.
SERIAL NO.		
N.B.		

WL-786-B		REV. 4-13-09
		DATE: 1-15-07
FOR: .		
VERT. CHILLED WATER TANK		
INSIDE: UNPAINTED		
OUTSIDE: SHOP PRIME		
BY: J.G. / B.C.	SCALE: 1"=12"	
ROY E. HANSON JR. MFG.		
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021		