



NOTE: 1) 2) WELD 3/4" ϕ ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
HYDRO @ 195 PSIG. MIN.

SHELL / HEADS	
JOGGLE	.164" SA-414-G 2:1 S.E.
	.135" SA-414-G
M.A.W.P.	150 PSIG. @ 150 °F
M.D.M.T.	0 °F @ 150 PSIG.
ASME. SECTION VIII	DIV. 1, 2007 ADD 2008
X-RAY:	RT-NO
GALLONS:	120 WT. 312 LBS.
SERIAL NO.	
N.B.	
WL-859-B	
FOR: -	REV. 10-5-09
VERT. CHILLED WATER TANK	DATE: 3-19-07
SURFACE AREA = 35.9 SQ. FT.	
INSIDE: UNPAINTED	
OUTSIDE: PRIME	
BY: E.S. / R.L.	SCALE: 1"=12"
ROY F. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	