





VIEW W/OUT SUPT'S

2) WELD 3/4"ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

NOTE: 1) HYDRO @ 164 PSIG. MIN.

SHELL / HEADS	.166" SA-414-G 2:1 S.E.	WM-249-B	REV.
	JOGGLE		DATE: 3-26-08
		FOR: -	
		HORIZ. CHILLED WATER TANK	
	.165" SA-414-G	SURFACE AREA = 73.0 SQ. FT.	
		INSIDE: UNPAINTED	
M.A.W.P. 125 PSIG. @ 200 °F			
M.D.M.T. 0 °F @ 125 PSIG.		OUTSIDE: SAND BLAST	
ASME. SECTION VIII DIV. 1, 2007 ADD 2007		-	
X-RAY: RT-NO		BY: J.G./STEVE	SCALE: 1"=12"
GALLONS: 300	WT. 627 LBS.	ROY E. HANSON JR. MFG.	
SERIAL NO.		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	
N.B.			