



SHELL / HEADS		NOTE: 1) 2) WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.	
M.A.W.P.	125 PSIG. @ 200 °F	.182" SA-455	2:1 S.E.
M.D.M.T.	0 °F @ 125 PSIG.	JOGGLE - .149	OFFSET
ASME SECTION VIII	DIV. 1, 2007 ADD. 2009	.165" SA-414-G	
X-RAY:	RT-NO		
GALLONS:	400	WT.	889 LBS.
SERIAL NO.			
N.B.			
INSIDE: UNPAINTED		WM-585-B	
OUTSIDE: SHOP PRIME		REV. 7-23-10	
FOR: CAL HYDRONICS		DATE: 1-28-09	
VERT. CHILLED WATER TANK			
SURFACE AREA = 83.1 SQ. FT.			
BY: J.G./C.J.		SCALE: 3/4"=12"	
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			