





VIEW W/OUT SUPPORTS

4) 4-1-04 PROOF TEST.
3) EXTEND ALL CPLGS. 5/8" INSIDE.
2) HYDRO @ 240 PSIG. MIN.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

SHELL / HEADS	.166" SA-414-G 2:1 S.E.	CS-30-235-H	REV. 9-14-04
	JOGGLE		DATE: 10-24-89
		FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
	.165" SA-414-G	58.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
M.A.W.P. 160 PSIG. @ 210 °F		INSIDE: CEMENT LINED (222)	
ASME. SECTION IV 2001 ADD 2003		OUTSIDE: PRIME	
X-RAY: RT-NO / H.L.W.		CAD-"B" UNDER "STD"-SERIES	
GALLONS: 235	WT. 952 LBS.	BY: E.S.	SCALE: 1"=12"
SERIAL NO.		ROY E. HANSON JR. MFG.	
N.B.		1924 COMPTON AVE. LOS ANGELES, CA 90011	