



NOTE: 1) 2) SHELL - 4-22-04 PROOF TEST.
HYDRO @ 240 PSIG.

SHELL / HEADS	
.250" SA-414-G 2:1 S.E.	ES-48-1080-H
JOGGLE - .208 OFFSET	REV. 5-22-09
.200" SA-455	DATE: 10-3-89
M.A.W.P. 160 PSIG. @ 180 °F	FOR: HANSON STANDARD
ASME SECTION IV 2007 ADD. 2008	HORIZ. HOT WATER TANK
X-RAY: RT-NO/H.L.W.	SURFACE AREA = 162.1 SQ. FT.
GALLONS: 1080 WT. 1600 LBS.	INSIDE: EPOXY LINED
SERIAL NO.	OUTSIDE: PRIME
	CAD-"B" UNDER "STD"-SERIES
	BY: J.G. SCALE: 3/4"=12"
	ROY E. HANSON JR. MFG.
	1600 E. WASHINGTON BLVD.
	LOS ANGELES, CA 90021

END VIEW W/O SUPPORTS