



2) 4-22-04 PROOF TEST.
 NOTE: 1) HYDRO @ 240 PSIG.

SHELL / HEADS	.245" SA-455 2:1 S.E.	ES-48-800-V	REV. 1-23-07
	JOGGLE - .208 OFFSET		DATE: 9-6-89
	.200" SA-455	FOR: HANSON STANDARD VERT. WATER TANK.	
		SURFACE AREA = 125.3 SQ. FT. INSIDE: EPOXY LINED	
		OUTSIDE: PRIME	
		LEG-ZONE 4-15 KM.	
		CAD-"B" UNDER "STD"-SERIES	
		BY: J.G.	SCALE: 3/4" = 1'
		ROY E. HANSON JR. MFG.	
		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	
M.A.W.P.	160 PSIG. @ 180 °F		
ASME. SECTION	IV 2004 ADD. 2006		
X-RAY:	RT-NO / H.L.W.		
GALLONS:	800	WT. 1271 LBS.	
SERIAL NO.			
N.B.			

11" \times 15" H.HOLE W/ 3/4" \times 3" LG. GR.70 RING
 1/2" STICK OUT