



NOTE: 1) HYDRO @ 325 PSIG. MIN.

| | |
|-------------------|----------------------------|
| SHELL / HEADS | .245" SA-455 2:1 S.E. |
| JOGGLE | |
| | .288" SA-455 |
| M.A.W.P. | 250 PSIG. @ 200 °F |
| M.D.M.T. | -20 °F @ 250 PSIG. |
| ASME SECTION VIII | DIV. 1, 2001 ADD. 2003 |
| X-RAY: | RT-4 SPOT L.S. & HDS. G.S. |
| GALLONS: | 575 WT. 1540 LBS. |
| SERIAL NO. | |
| N.B. | |

| | |
|-------------------------------|---------------|
| PA-496-B | REV. 9-2-04 |
| FOR: HANSON STANDARD | DATE: 7-31-03 |
| HORIZ. PROPANE TANK DISPENSER | |
| CFM REQ. = 2407 | |
| SURFACE AREA = 103.2 SQ. FT. | |
| INSIDE: UNPAINTED & DEHYDRATE | |
| OUTSIDE: PRIME | |
| BY: J.G. | |
| ROY E. HANSON JR. MFG. | |
| 1924 COMPTON AVE. | |
| LOS ANGELES, CA 90011 | |